

Ymane Bouramia

From: Barbara Laughlin
Sent: Monday, June 27, 2005 9:14 AM
To: Ymane Bouramia
Subject: FW: Supplemental EPA Review Comments

-----Original Message-----

From: Alan Hanscom
Sent: Monday, May 16, 2005 12:36 PM
To: Kimberly Tisa (tisa.kimberly@epa.gov)
Cc: Jackie Huggins; Scott Alfonse (ScottA@ci.new-bedford.ma.us); Evan Warner (ewarner@mvgarchitects.com); Cyndee Fuller(cf Fuller@essgroup.com); 'Al Amaral'
Subject: Supplemental EPA Review Comments

As discussed last Thursday, the following additional review comments have been provided by EPA:

1. Risk Assessment Memo dated May 9, 2005 - Attachment A, not "Appendix A" - provided with original submittal - **RESOLVED**
2. Vent stack locations with respect to HVAC Units - We will provide site plan indicated locations of vents and HVAC units.
3. Analyses for Asbestos - No overt signs of asbestos containing materials (to be documented).
4. RBCR Attachment D did not contain CD of analytical results - Two CDs to be provided.

All requested information will be submitted on Tuesday, May 17th. Please call me with any further questions.

Alan D. Hanscom, P.E., LS
Associate
BETA Group, Inc.
315 Norwood Park South
Norwood, Massachusetts 02062
Tel: 781/255-1982
Fax: 781/255-1974
Cell: 617/699-1878